

Bid Addendum

Addendum No. 2 for HRRSA Blacks Run Interceptor Division 1A Rehabilitation, ITB No. HRRSA-2020-02, Wiley|Wilson Comm. No. 217171.00.

Addendum Date: June 16, 2020
To: All Bidding Contractors
From: Wiley|Wilson
Lynchburg, VA

This Addendum contains 2 pages and listed attachments and forms a part of the bidding documents and modifies the Project Manual and Drawings dated May 15, 2020, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

1. A revised Section 000400.2 Major Equipment and Product Schedule is attached that includes Liner Products LLC.

RESPONSE TO QUESTIONS

Question 1: Do you have a spec for the manhole rehab you can provide?

Response: Refer to Spec 330130.71, 3.10, A. 'Or Equal' products will be approved if they meet or exceed the performance characteristics of the specified product.

Question 2: If possible, would the Owner make available the recorded pre-bid video conference from May 28th, 2020?

Response: The pre-bid conference was not recorded.

Question 3: Plan sheet C-101 states "Coordinate access with Owner (George's Family Farms LLC)" Would the Owner confirm that there is an existing easement agreement with George's Family Farm LLC?

Response: HRRSA has an existing sanitary sewer easement that allows direct access to the easement through the existing property entrance. During construction, the Contractor will be responsible for coordinating access to the easement with George's Family Farms to ensure minimum impact to the property owner.

Question 4: Would the Owner make available any CCTV of the 36" diameter pipeline prior to bid? This would allow bidders may review the videos for issues that may require additional costs, for instance, removing heavy debris or mitigating heavy infiltration.

Response: CCTV is not available.

Question 5: Would the Owner provide a schedule of values or a unit price bid schedule to

ensure all bidders are pricing the same work; as well as, establish unit prices in case there are changes in quantity during construction?

Response: This project requires lump sum pricing as shown in the contract documents.

Question 6: Supplementary Conditions Article 7 SC-7.03.C states “Regular working hours will be 8am to 5pm” Section SC-7.03.D state “Contractor shall be responsible for the cost of any overtime pay . . . “ Due to the lengthy nature of larger diameter CIPP curing schedules, around the clock work will be required. Would the Owner confirm 24-hour work will be allowed and provide the overtime cost the constructor should consider?

Response: Continuous work (24 hour) will be allowed subject to noise restrictions and other restrictions to meet City of Harrisonburg ordinances and policies. Overtime costs for construction observation will be \$100 per hour.

Question 7: Would the Owner list any required permits that the Contractor will be required to obtain during construction?

Response: The Contractor is responsible for familiarizing themselves with permit requirements for the project. HRRSA has submitted plans to the City of Harrisonburg Community Development. The Contractor is responsible for obtaining a land disturbance permit and paying all applicable fees. A DEQ Certificate to Construct is not required for this project.

Question 8: The General Terms and Conditions states “Sales to HRRSA are normally exempt from State sales tax.” Would the Owner confirm sales tax is exempt for this project?

Response: Refer to C-800 Supplemental Conditions SC-7.10.

Question 9: Section 00400.2 list CIPP products that are specific to individual CIPP installers and are not readily available to the open market for purchase. Bidders may provide ‘Or Equal’; however, section 00400.2 requires the Bidder to circle one of the named products as base product. Since installing this base product cannot be purchased readily, could alternative products be submitted and pre-approved prior to bid?


Response: The Bid Form contains Section 00400.3 that allows Bidders to proposal “alternate” or “or-equal” products.

ATTACHMENTS

1. Section 000400.2 Major Equipment and Product Schedule

End of Addendum No. 2

Wiley|Wilson



Aaron Tice, P.E.

SECTION 00400.2 MAJOR EQUIPMENT AND PRODUCT SCHEDULE

All items on the Major Equipment and Product Schedule shall be bid according to the following:

The Major Equipment and Product Schedule designates major equipment items to be provided. The bidder shall indicate which of the specified manufacturers/supplier's equipment it is offering to provide by circling one of the named manufacturers/suppliers listed. A named manufacturer/supplier for each identified major equipment item shall be circled, even if only one is specified.

If the bidder desires to propose a "or equal" and/or "substitute" for any named manufacturer/supplier of a specified item, it shall circle the named manufacturer/supplier (in the major equipment schedule) it is offering to provide and also shall write in the space/form provided the name of the offered "or equal" and/or "substitute" manufacturer/supplier and provide for such the price deduction resulting to the Owner upon the allowed use of the "or equal" and/or "substitute". Named manufacturers/suppliers are defined as those listed in the major equipment schedule. Or equal and/or substitute manufacturers/suppliers are defined as those proposed and written in by the bidder in the space so designated. Should the "or equal" and/or "substitute" manufacturer/supplier be determined "not equal" in the Owner/Engineer's discretion, the bidder must provide the named manufacturer/supplier circled in the major equipment schedule.

Should the bidder fail to indicate the named manufacturer/supplier on which its bid is based, or circle more than one named manufacturer/supplier per equipment item, the bid shall be deemed to have been based upon the first listed manufacturer in the Schedule, and the bidder, if awarded the contract, shall provide the first of the listed named manufacturers/suppliers for that item.

| Equipment | Named Product |
|--|----------------------|
| Section 33 01 30.71 Sewer Rehabilitation | Insituform |
| | Saertex |
| | National Liner |
| | Masterliner |
| | Reline America |
| | Liner Products LLC |