

ADDENDUM No. 2

HRRSA RFP 2020-01 Tertiary Filter Phase III Upgrade

Prepared for

Harrisonburg-Rockingham Regional Sewer Authority

P.O. Box 8
Mt. Crawford, Virginia 22841



Prepared by

Mangrum Consulting & Design
1500 Clayton Avenue
Lynchburg, Virginia 24503



Addendum Date: December 13, 2019

This Addendum No. 2, dated December 13, 2019 amends or supplements the Contract Documents titled HRRSA RFP 2020-01 Tertiary Filter Phase III Upgrade dated November 15, 2019 as indicated below.

QUESTIONS & RESPONSES

- **Question 1**: "Does the Owner furnished filter equipment require assembly ?"
- **Response 1**: "Yes, extensive assembly is required by the installing contractor as part of this project. Refer to Attachment A of the original RFP for the filter equipment operations, maintenance and installation manual."

CHANGES TO CONTRACT DOCUMENTS

- D-101 and D-301: Removal of filter media below the underdrain floor has been removed from the scope of project for all filter cells except cell 1C.
- D-101 and D-301: Saw cutting access ports in concrete underdrain floor for removing filter media below the concrete floor in cells 1A, 1B, 1D, 2B, AND 2D has been removed from the project scope.
- D-101 and D-301: Contractor to place all removed filter media at a location to be designated by the Owner located within the confines of the treatment plant site. Owner will be responsible for all further costs associated with filter media disposal.

Attachment(s)

none.

END OF ADDENDUM NO. 2
